

Navrh otopnych teles firmy K O R A D O a.s. Ceska Trebova

Akce : Byty-Vir
Datum : 24. 9.2012

Teplota topne vody - privodni : 65.0 oC
vratne : 50.0 oC
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	delka mm	vodni objem dm3	tepelny vykon W
101 Predsin-byt 1	18 65/50	11-060100-60-VK	1000	3.1	728
102 Pokoj-byt 1	20 65/50	22-060100-60-VK	1000	5.8	1128
102 Pokoj-byt 1	20 65/50	22-060100-60-VK	1000	5.8	1128
103 Koupelna-byt 1	24 65/50	KRC 1820.0600	595	8.2	559
104 WC-byt 1	20 65/50	11-060060-60-VK	600	1.9	407
105 Predsin-byt 2	18 65/50	11-050040-60-VK	400	1.1	249
106 Pokoj-byt 2	20 65/50	21-060110-60-VK	1100	6.4	953
107 Koupelna+WC-byt2	24 65/50	KRC 1500.0600	595	6.9	454
109 Predsin-byt 3	20 65/50	11-050040-60-VK	400	1.1	233
110 Koupelna-byt 3	24 65/50	KRC 1500.0600	595	6.9	454
112 Pokoj-byt 3	20 65/50	11-060100-60-VK	1000	3.1	679
113 Predsin-byt 4	20 65/50	11-050040-60-VK	400	1.1	233
114 Koupelna-byt 4	24 65/50	KRC 1500.0600	595	6.9	454
116 Pokoj-byt 4	20 65/50	11-060110-60-VK	1100	3.4	746

Otopne teleso --	vyska mm	delka mm	cena Kc/ks	Celkem pocet kusu	Celkem cena Kc	vodni objem dm3	tepelny vykon W
11-050040-60-VK	500	400	2052	3	6156	3.2	713
11-060060-60-VK	600	600	2523	1	2523	1.9	407
11-060100-60-VK	600	1000	3064	2	6128	6.2	1405
11-060110-60-VK	600	1100	3198	1	3198	3.4	746
21-060110-60-VK	600	1100	4022	1	4022	6.4	953
22-060100-60-VK	600	1000	4276	2	8552	11.6	2256
KRC 1500.0600	1500	595	1800	3	5400	20.7	1362
KRC 1820.0600	1820	595	2077	1	2077	8.2	559
Celkem okruh c. 1				14	38056	61.6	8401
Celkem objekt				14	38056	61.6	8401